

Farm Hazard Inspection Checklist

ELECTRICAL

Completed By: _____

Date: _____

BUILDING/AREA: _____

NOTE: Any items needing correction that could cause injury should be taken out of service and employees informed until repaired.

Items	Hazard		Action		Notes
	Yes	No	Target Date	Corrected	
Are all electrical cords and wiring in working order?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are exposed wiring and cords with frayed or deteriorated insulation repaired or replaced promptly?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are flexible cords and cables free of splices or taps?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are all cord, cable and raceway connections intact and secure?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are employees instructed to make preliminary inspections and/or appropriate tests to determine conditions before starting work on electrical equipment or lines?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
When electrical equipment or line are to be serviced, maintained, or adjusted, are necessary switches opened, locked out or tagged whenever possible?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are LO/TO devices available to qualified employees?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Is the use of metal ladders prohibited where the ladder or the person using the ladder could come in contact with energized parts or equipment, fixtures, or circuit conductors?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are portable electrical tools and equipment grounded or of the double insulated type?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are portable heaters and other heating equipment in good condition? Are they properly vented and kept away from combustibles?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are employees prohibited from working alone on energized lines or equipment over 600 volts?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	
Are employees who regularly work on or around energized electrical equipment or lines instructed in cardiopulmonary resuscitation (CPR)?	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	